

May - Jul 2007		POND SIX	POND SIX	POND SIX
		Enterococci	E.coli	Faecal Coliforms
Day	Date	MPN/100ml	CFU/100ml	CFU/100ml
Thursday	03.05.07	20	300	200
Monday	07.05.07	20	160	240
Thursday	10.05.07	20	400	220
Monday	14.05.07	<10	55	180
Thursday	17.05.07	10	150	150
Monday	21.05.07	<10	60	40
Thursday	24.05.07	72	20	36
Monday	28.05.07	41	260	370
Thursday	31.05.07	74	1400	2800
Monday	04.06.07	41	960	1100
Thursday	07.06.07	110	1200	1100
Monday	11.06.07	52	1000	1000
Thursday	14.06.07	510	1800	2500
Monday	18.06.07	270	520	740
Thursday	21.06.07	150	240	580
Monday	25.06.07	<20	100	290
Thursday	28.06.07	52	180	380
Monday	02.07.07	63	360	450
Thursday	05.07.07	52	360	480
Monday	09.07.07	20	450	1200
Thursday	12.07.07	190	2100	2900
Monday	16.07.07	85	560	1400
Thursday	19.07.07	51	380	1300
Monday	23.07.07	64	530	910
Thursday	26.07.07	41	340	660
Monday	30.07.07	30	820	1300

Consent Requirements Condition 16(d)

Based on twice weekly sampling no more than 6 values from 8 consecutive samples shall exceed the following standard values and no more than 2 values from 8 consecutive samples shall exceed the higher value.

	Standard Value		
	Summer	Winter	Winter
Faecal Coli MPN/100ml	5000	20,000	30,000

