



*The volume of treated wastewater discharged can exceed the consent limit of 1,500 cubic metres per day during rainfall events of a total of 50 millimetres or more over three consecutive days.*

Rainfall during consent limit exceedance days:

15/02/2023 52.2mm rainfall

21/05/2023 47.6 rainfall

9-11/07/2023 122.6mm rainfall

22-27/07/2023 261.2mm rainfall