

CRC940690A Lyttelton WWTP

Sampling: Mar - Nov: Monthly, Dec & Feb: Weekly,
Jan: 5 in 30 days

Sample Date	Faecal coliforms	Median faecal coliforms	Consented median limit	OK? <1000
24/08/2021	10	10	1000	YES
21/09/2021	10	10	1000	YES
26/10/2021	10	10	1000	YES
9/11/2021	10	10	1000	YES
3/12/2021	10	10	1000	YES
9/12/2021	10	10	1000	YES
15/12/2021	10	10	1000	YES
22/12/2021	10	10	1000	YES
31/12/2021	10	10	1000	YES
5/01/2022	10	10	1000	YES
13/01/2022	10	10	1000	YES
19/01/2022	10	10	1000	YES
26/01/2022	10	10	1000	YES
1/02/2022	10	10	1000	YES
10/02/2022	10	10	1000	YES
16/02/2022	10	10	1000	YES
24/02/2022	10	10	1000	YES
3/03/2022	10	10	1000	YES
28/04/2022	10	10	1000	YES
23/05/2022	10	10	1000	YES
9/06/2022	10	10	1000	YES
19/07/2022	10	10	1000	YES
15/08/2022	10	10	1000	YES
5/09/2022	5	10	1000	YES
3/10/2022	10	10	1000	YES
15/11/2022	600	10	1000	YES
21/11/2022	10	10	1000	YES
5/12/2022	10	10	1000	YES
9/12/2022	10	10	1000	YES
16/12/2022	5	10	1000	YES
23/12/2022	10	10	1000	YES
30/12/2022	10	10	1000	YES