

May - July 2010		POND SIX	POND SIX	POND SIX
		Enterococci	E.coli	Faecal Coliforms
Day	Date	MPN/100ml	CFU/100ml	CFU/100ml
Thursday				
Monday	03.05.10	60	500	350
Thursday	06.05.10	31	220	380
Monday	10.05.10	52	700	440
Thursday	13.05.10	340	660	540
Monday	17.05.10	360	56	52
Thursday	20.05.10	200	360	420
Monday	24.05.10			
Thursday	27.05.10			
Monday	31.05.10			
Thursday	03.06.10			
Monday	07.06.10			
Thursday	10.06.10			
Monday	14.06.10			
Thursday	17.06.10			
Monday	21.06.10			
Thursday	24.06.10			
Monday	28.06.10			
Thursday	01.07.10			
Monday	05.07.10			
Thursday	08.07.10			
Monday	12.07.10			
Thursday	15.07.10			
Monday	19.07.10			
Thursday	22.07.10			
Monday	26.07.10			
Thursday	29.07.10			

Consent Requirements Condition 16(d)

Based on twice weekly sampling no more than 6 values from 8 consecutive samples shall exceed the following standard values and no more than 2 values from 8 consecutive samples shall exceed the higher value.

	Standard Value		
	Summer	Winter	Winter
Faecal Coli MPN/100ml	5000	20,000	30,000